



Kristianstad, Sweden 2009-06-29

Smokeless Heat
2020 Cornwall Road
Lebanon, Pa 17042, USA

Dear Sirs,

Värmebaronen hereby confirms the efficiency for the below mentioned boilers. These figures have been confirmed by tests carried out by laboratories including Swedish Test Institute (SP), Danish Technological Institute and TÜV.

<u>Boiler</u>	<u>Efficiency</u>
Vedolux 350	93%
Vedolux 450	92%
Vedolux 650	91%
Vedolux 30 and 37	86%
Vedolux 55	87%
Vedolux 40, 50 and 30 CU	78%
PellmaxUB/Viking Bio	92%

A handwritten signature in blue ink, appearing to read 'Jens Svensson', is written over a horizontal line.

Jens Svensson / Export Manager
Värmebaronen AB